



NSAI
Standards

Irish Standard
I.S. EN 55016-2-2:2011

Specification for radio disturbance and immunity measuring apparatus and methods -- Part 2-2: Methods of measurement of disturbances and immunity - Measurement of disturbance power (CISPR 16-2-2:2010 (EQV))

I.S. EN 55016-2-2:2011

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<p><i>This document replaces:</i> EN 55016-2-2:2004 + A1:2005 + A2:2005</p>	<p><i>This document is based on:</i> EN 55016-2-2:2011</p>	<p><i>Published:</i> 1 April, 2011</p>
<p>This document was published under the authority of the NSAI and comes into effect on: 8 April, 2011</p>		<p>ICS number: 33.100.10 33.100.20</p>
<p>NSAI 1 Swift Square, Northwood, Santry Dublin 9</p>	<p>T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie</p>	<p>Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie</p>
<p>Údarás um Chaighdeáin Náisiúnta na hÉireann</p>		

English version

**Specification for radio disturbance and immunity measuring apparatus
and methods -
Part 2-2: Methods of measurement of disturbances and immunity -
Measurement of disturbance power
(CISPR 16-2-2:2010)**

Spécifications des méthodes et des
appareils de mesure des perturbations
radioélectriques et de l'immunité aux
perturbations radioélectriques -
Partie 2-2: Méthodes de mesure des
perturbations et de l'immunité -
Mesure de la puissance perturbatrice
(CISPR 16-2-2:2010)

Anforderungen an Geräte und
Einrichtungen sowie Festlegung der
Verfahren zur Messung der
hochfrequenten Störaussendung
(Funkstörungen) und Störfestigkeit -
Teil 2-2: Verfahren zur Messung der
hochfrequenten Störaussendung
(Funkstörungen) und Störfestigkeit -
Messung der Störleistung
(CISPR 16-2-2:2010)

This European Standard was approved by CENELEC on 2011-01-02. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document CISPR/A/877/CDV, future edition 2 of CISPR 16-2-2, prepared by CISPR SC A, Radio-interference measurements and statistical methods, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 55016-2-2 on 2011-01-02.

This European Standard supersedes EN 55016-2-2:2004 + A1:2005 + A2:2005.

This EN 55016-2-2:2011 includes the following significant technical changes with respect to EN 55016-2-2:2004 + A1:2005 + A2:2005: provisions for the use of spectrum analyzers for compliance measurements (Annex D) and the use of FFT-based test instrumentation (Clauses 3, 6 and 8) are now included.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2011-10-02
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2014-01-02

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard CISPR 16-2-2:2010 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- [1] CISPR 13 NOTE Harmonized as EN 55013.
- [2] CISPR 14-1:2005 NOTE Harmonized as EN 55014-1:2006 (not modified).
- [3] CISPR 16-2-1:2008 NOTE Harmonized as EN 55016-2-1:2009 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
CISPR 16-1-1	2010	Specification for radio disturbance and immunity measuring apparatus and methods - Part 1-1: Radio disturbance and immunity measuring apparatus - Measuring apparatus	EN 55016-1-1	2010
CISPR 16-1-3	2004	Specification for radio disturbance and immunity measuring apparatus and methods - Part 1-3: Radio disturbance and immunity measuring apparatus - Ancillary equipment - Disturbance power	EN 55016-1-3	2006
CISPR 16-1-4	- ¹⁾	Specification for radio disturbance and immunity measuring apparatus and methods - Part 1-4: Radio disturbance and immunity measuring apparatus - Antennas and test sites for radiated disturbance measurements	EN 55016-1-4	2010 ²⁾
CISPR 16-4-2	- ¹⁾	Specification for radio disturbance and immunity measuring apparatus and methods - Part 4-2: Uncertainties, statistics and limit modelling - Uncertainty in EMC measurements	EN 55016-4-2	2004 ²⁾
IEC 60050-161	1990	International Electrotechnical Vocabulary (IEV) - Chapter 161: Electromagnetic compatibility	-	-

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

This page is intentionally left BLANK.

CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references.....	7
3 Terms and definitions	7
4 Types of disturbance to be measured.....	12
4.1 General	12
4.2 Types of disturbance	12
4.3 Detector functions	12
5 Connection of measuring equipment	13
5.1 General	13
5.2 Connection of ancillary equipment.....	13
6 General measurement requirements and conditions	13
6.1 General	13
6.2 Disturbance not produced by the equipment under test	13
6.2.1 General	13
6.2.2 Compliance testing	13
6.3 Measurement of continuous disturbance	13
6.3.1 Narrowband continuous disturbance.....	13
6.3.2 Broadband continuous disturbance.....	14
6.3.3 Use of spectrum analyzers and scanning receivers.....	14
6.4 Operating conditions of the EUT	14
6.4.1 General	14
6.4.2 Normal load conditions.....	14
6.4.3 The time of operation.....	14
6.4.4 Running-in time	14
6.4.5 Supply	14
6.4.6 Mode of operation.....	14
6.5 Interpretation of measuring results.....	14
6.5.1 Continuous disturbance	14
6.5.2 Discontinuous disturbance	15
6.5.3 Measurement of the duration of disturbances	15
6.6 Measurement times and scan rates for continuous disturbance	15
6.6.1 General	15
6.6.2 Minimum measurement times	15
6.6.3 Scan rates for scanning receivers and spectrum analyzers	16
6.6.4 Scan times for stepping receivers	17
6.6.5 Strategies for a spectrum overview using the peak detector.....	18
6.6.6 Timing considerations using FFT-based instruments	21
7 Measurements using the absorbing clamp.....	23
7.1 Introduction to ACMM	23
7.2 Application of the absorbing clamp measurement method	24
7.2.1 General	24
7.2.2 Frequency range.....	24
7.2.3 EUT unit dimensions.....	24
7.2.4 LUT requirements	24
7.3 Requirements for measurements instrumentation and test site	24

7.3.1	General	24
7.3.2	Measuring receiver	24
7.3.3	Absorbing clamp assembly.....	24
7.3.4	Absorbing clamp test site requirements	25
7.4	Ambient requirements	26
7.5	EUT leads requirements	26
7.5.1	General	26
7.5.2	Lead under test.....	26
7.5.3	Leads not under test	27
7.6	Test set-up requirements	27
7.6.1	General	27
7.6.2	EUT set-up	27
7.6.3	LUT set-up.....	28
7.6.4	Absorbing clamp	29
7.6.5	Measurement cable.....	29
7.7	Operating conditions of the EUT	29
7.8	Measurement procedure	29
7.8.1	Ambient measurement procedure.....	29
7.8.2	EUT measurement procedure	29
7.9	Determination of disturbance power	31
7.10	Determination of the measurement uncertainty.....	31
7.11	Compliance criteria.....	31
8	Automated measurement of emissions.....	32
8.1	Precautions for automating measurements.....	32
8.2	Generic measurement procedure	32
8.3	Prescan measurements	33
8.3.1	Purpose.....	33
8.3.2	Determination of the required measurement time	33
8.3.3	Defining the prescan measurement	33
8.4	Data reduction	34
8.5	Emission maximization and final measurement	34
8.6	Post processing and reporting.....	34
8.7	Emission measurement strategies with FFT-based measuring instruments.....	34
Annex A (informative) Historical background to the method of measurement of the interference power produced by electrical household and similar appliances in the VHF range (see 7.1)		35
Annex B (informative) Use of spectrum analyzers and scanning receivers (see Clause 6)		38
Annex C (informative) Scan rates and measurement times for use with the average detector		41
Annex D (normative) Determination of suitability of spectrum analyzers for compliance tests.....		45
Bibliography		46
Figure 1 – Measurement of a combination of a CW signal (“NB”) and an impulsive signal (“BB”) using multiple sweeps with maximum hold.....		18
Figure 2 – Example of a timing analysis.....		19
Figure 3 – A broadband spectrum measured with a stepped receiver		20
Figure 4 – Intermittent narrowband disturbances measured using fast short repetitive sweeps with maximum hold function to obtain an overview of the emission spectrum		20

Figure 5 – FFT scan in segments	22
Figure 6 – Frequency resolution enhanced by FFT-based measuring instrument	23
Figure 7 – Schematic drawing of the absorbing clamp measurement method	25
Figure 8 – Side view of the absorbing clamp measurement set-up for table top EUTs	28
Figure 9 – Side view of the absorbing clamp measurement set-up for floor standing EUTs	28
Figure 10 – Process for reduction in measurement time.....	32
Figure C.1 – Weighting function of a 10 ms pulse for peak (“PK”) and average detections with (“CISPR AV”) and without (“AV”) peak reading; meter time constant 160 ms.....	43
Figure C.2 – Weighting functions of a 10 ms pulse for peak (“PK”) and average detections with (“CISPR AV”) and without (“AV”) peak reading; meter time constant 100 ms.....	43
Figure C.3 – Example of weighting functions (of a 1 Hz pulse) for peak (“PK”) and average detections as a function of pulse width: meter time constant 160 ms.....	44
Figure C.4 – Example of weighting functions (of a 1 Hz pulse) for peak (“PK”) and average detections as a function of pulse width: meter time constant 100 ms.....	44
Table 1 – Minimum measurement times for the four CISPR bands	16
Table 2 – Minimum scan times for the three CISPR bands with peak and quasi-peak detectors.....	16
Table 3 – Sample scheme for an absorbing clamp measurement with an upper frequency bound of 300 MHz.....	30
Table 4 – Sample scheme for an absorbing clamp measurement with an upper frequency bound of 1 000 MHz.....	31
Table B.1 – Minimum sweep time/fastest scan rates	39
Table C.1 – Pulse suppression factors and scan rates for a 100 Hz video bandwidth.....	42
Table C.2 – Meter time constants and the corresponding video bandwidths and maximum scan rates	42
Table D.1 – Maximum amplitude difference between peak and quasi-peak detected signals	45

INTERNATIONAL ELECTROTECHNICAL COMMISSION
INTERNATIONAL SPECIAL COMMITTEE ON RADIO INTERFERENCE

**SPECIFICATION FOR RADIO DISTURBANCE AND IMMUNITY
MEASURING APPARATUS AND METHODS –**

**Part 2-2: Methods of measurement of disturbances and immunity –
Measurement of disturbance power**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard CISPR 16-2-2 has been prepared by CISPR subcommittee A: Radio-interference measurements and statistical methods, in cooperation with CISPR subcommittee D: Electromagnetic disturbances related to electric/electronic equipment on vehicles and internal combustion engine powered devices.

This second edition cancels and replaces the first edition (2003), its Amendment 1 (2004) and Amendment 2 (2005). It constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition: provisions for the use of spectrum analyzers for compliance measurements (Annex D) and the use of FFT-based test instrumentation (Clauses 3, 6 and 8) are now included.

It has the status of a basic EMC publication in accordance with IEC Guide 107, *Electromagnetic compatibility – Guide to the drafting of electromagnetic compatibility publications*.

The text of this standard is based on the following documents:

CDV	Report on voting
CISPR/A/877/CDV	CISPR/A/896/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the CISPR 16 series can be found on the IEC website under the general title *Specification for radio disturbance and immunity measuring apparatus and methods*.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-