



NSAI
Standards

Irish Standard
I.S. EN 60934:2001

Circuit-breakers for equipment (CBE) (IEC 60934:2000 (EQV))

I.S. EN 60934:2001

Incorporating amendments/corrigenda issued since publication:

EN 60934:2001/A2:2013

EN 60934:2001/A1:2007

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i>	<i>This document is based on:</i> EN 60934:2001	<i>Published:</i> 26 January, 2001
This document was published under the authority of the NSAI and comes into effect on: 15 June, 2001		ICS number: 29.120.40 29.120.50
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeán Náisiúnta na hÉireann		

I.S. EN 60934:2001

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60934/A2

April 2013

ICS 29.120.40; 29.120.50

English version

Circuit-breakers for equipment (CBE)
(IEC 60934:2000/A2:2013)

Disjoncteurs pour équipement (DPE)
(CEI 60934:2000/A2:2013)

Geräteschutzschalter (GS)
(IEC 60934:2000/A2:2013)

This amendment A2 modifies the European Standard EN 60934:2001; it was approved by CENELEC on 2013-02-22. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 23E/767/FDIS, future edition 1 of IEC 60934:2000/A2, prepared by SC 23E, "Circuit-breakers and similar equipment for household use", of IEC TC 23, "Electrical accessories" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 60934:2001/A2:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-11-22
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-02-22

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 60934:2000/A2:2013 was approved by CENELEC as a European Standard without any modification.

I.S. EN 60934:2001

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60934/A1

February 2007

ICS 29.120.50; 29.120.40

English version

Circuit-breakers for equipment (CBE)
(IEC 60934:2000/A1:2007)

Disjoncteurs pour équipement (DPE)
(CEI 60934:2000/A1:2007)

Geräteschutzschalter (GS)
(IEC 60934:2000/A1:2007)

This amendment A1 modifies the European Standard EN 60934:2001; it was approved by CENELEC on 2007-02-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

I.S. EN 60934:2001

EN 60934:2001/A1:2007

- 2 -

Foreword

The text of document 23E/624/FDIS, future amendment 1 to IEC 60934:2000, prepared by SC 23E, Circuit-breakers and similar equipment for household use, of IEC TC 23, Electrical accessories, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as amendment A1 to EN 60934:2001 on 2007-02-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2007-11-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2010-02-01

Endorsement notice

The text of amendment 1:2007 to the International Standard IEC 60934:2000 was approved by CENELEC as an amendment to the European Standard without any modification.

I.S. EN 60934:2001

EUROPEAN STANDARD

EN 60934

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 2001

ICS 29.120.40;29.120.50

Supersedes EN 60934:1994 + A1:1994 + A2:1997 + A11:1998

English version

Circuit-breakers for equipment (CBE)
(IEC 60934:2000)

Disjoncteurs pour équipement (DPE)
(CEI 60934:2000)

Geräteschutzschalter (GS)
(IEC 60934:2000)

This European Standard was approved by CENELEC on 2000-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 23E/430/FDIS, future edition 3 of IEC 60934, prepared by SC 23E, Circuit-breakers and similar equipment for household use, of IEC TC 23, Electrical accessories, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60934 on 2000-11-01.

This European Standard supersedes EN 60934:1994 + A1:1994 + A2:1997 + A11:1998.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2001-08-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2003-11-01

Annexes designated "normative" are part of the body of the standard.

Annexes designated "informative" are given for information only.

In this standard, annexes A, B, C, D, E, G, H, J, K and ZA are normative and annex F is informative.

Annex ZA has been added by CENELEC.

In this standard the following print types are used:

- requirements: in roman type;
- *test specifications: in italic type;*
- notes: in smaller roman type.

Endorsement notice

The text of the International Standard IEC 60934:2000 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-151	1978	International Electrotechnical Vocabulary (IEV) Chapter 151: Electrical and magnetic devices	-	-
IEC 60050-441	1984	Chapter 441: Switchgear, controlgear and fuses	-	-
IEC 60050-604	1987	Chapter 604: Generation, transmission and distribution of electricity - Operation	-	-
IEC 60050-826	1982	Chapter 826: Electrical installations of buildings		
+ A1	1990			
+ A2	1995			
+ A3	1999		HD 384.2 S2	2001
IEC 60060-1	1989	High-voltage test techniques	HD 588.1 S1	1991
+ corr. March	1990	Part 1: General definitions and test requirements		
IEC 60068-2-20	1979	Basic environmental testing procedures Part 2: Tests - Test T: Soldering	HD 323.2.20 S3 ¹⁾	1988
IEC 60099-1	1991	Surge arresters Part 1: Non-linear resistor type gapped surge arresters for a.c. systems	EN 60099-1	1994
IEC 60227	Series	Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V	HD 21 ²⁾	Series
IEC 60269	Series	Low-voltage fuses	EN 60269	Series

¹⁾ HD 323.2.20 S3 includes A2:1987 to IEC 60068-2-20.

²⁾ The HD 21 series is related to but not equivalent to the IEC 60227 series.

I.S. EN 60934:2001

- 4 -

EN 60934:2001

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60417-1	1998	Graphical symbols for use on equipment Part 1: Overview and application	EN 60417-1	1999
IEC 60529	1989	Degrees of protection provided by enclosures (IP Code)	EN 60529 + corr May	1991 1993
IEC 60664	Series	Insulation coordination for equipment within low-voltage systems	-	-
IEC 60664-1 (mod)	1992	Part 1: Principles, requirements and tests	HD 625.1 S1 + corr. November	1996 1996
IEC 60664-3	1992	Part 3: Use of coatings to achieve insulation coordination of printed board assemblies	HD 625.3 S1	1997
IEC 60695-2-1/X	Series	Fire hazard testing Part 2: Test methods - Section 1: Glow- wire test methods	EN 60695-2-1/X ³⁾	Series
IEC 60898	1995 ⁴⁾	Electrical accessories - Circuit-breakers for overcurrent protection for household and similar installations	-	-
IEC 60947-1 (mod)	1999	Low-voltage switchgear and controlgear Part 1: General rules	EN 60947-1 + corr. October	1999 1999
IEC 60950 (mod) + corr. January	1999 2000	Safety of information technology equipment	EN 60950	2000
IEC 61000-4-2	1995	Electromagnetic compatibility (EMC) Part 4-2: Testing and measurement techniques - Electrostatic discharge immunity test	EN 61000-4-2	1995
IEC 61000-4-3 (mod)	1995	Part 4-3: Testing and measurement techniques - Radiated, radio-frequency, electromagnetic field immunity test	EN 61000-4-3	1996
IEC 61000-4-4	1995	Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test	EN 61000-4-4	1995
IEC 61000-4-5	1995	Part 4-5: Testing and measurement techniques - Surge immunity test	EN 61000-4-5	1995
CISPR 22 (mod)	1997	Information technology equipment - Radio disturbance characteristics - Limits and methods of measurement	EN 55022 + corr. August	1998 1999

³⁾ EN 60695-2-1/X:1996 are superseded by EN 60695-2-10:2001 to EN 60695-2-13:2001, which are based on IEC 60695-2-10:2000 to IEC 60685-2-13:2000.

⁴⁾ IEC 60898:1987 + corrigendum May 1988 + A2:1990 + A3:1990 + corrigendum August 1990, mod., are harmonized as EN 60898:1991. This European Standard applies with its corrigendum October 1991 and its amendments A1:1991 (IEC/A1:1989) and A11:1994 up to A19:2000.

CONTENTS

FOREWORD	6
1 Scope	8
2 Normative references	9
3 Definitions	10
3.1 Definitions related to protection and switching devices	10
3.2 General terms	11
3.3 Definitions related to current	12
3.4 Definitions related to voltage	13
3.5 Definitions related to constructional elements of a CBE	13
3.6 Definitions related to releases in CBEs	15
3.7 Definitions related to insulation and clearances in a CBE	16
3.8 Definitions related to operation of CBEs	18
3.9 Definitions related to the operating characteristic of CBEs	19
3.10 Definitions related to characteristic quantities	19
3.11 Definitions concerning coordination of CBEs and SCPDs associated in the same circuit	20
3.12 Definitions related to terminals and terminations	21
3.13 Definitions related to tests	23
4 Classification	24
4.1 Quantity of poles	24
4.2 Method of mounting	24
4.3 Method of connection	24
4.4 Method of operation	24
4.5 Mode of tripping	24
4.6 Influence of the ambient temperature	25
4.7 Trip-free behaviour	25
4.8 Influence of the mounting position	25
4.9 Electrical performance	25
5 Characteristics of CBEs	25
5.1 List of characteristics	25
5.2 Rated quantities	26
5.3 Standard and preferred values	27
6 Marking and other product information	28
7 Standard conditions for operation in service	29
7.1 Ambient air temperature	29
7.2 Altitude	29
7.3 Atmospheric conditions	30
8 Requirements for construction and operation	30
8.1 Mechanical design	30
8.2 Protection against electric shock	42
8.3 Temperature-rise	42
8.4 Dielectric properties	43
8.5 Conditions for automatic operation	44

I.S. EN 60934:2001

60934 © IEC:2000+A1:2007+A2:2013

– 3 –

2	8.6	Electrical performance and behaviour at rated short-circuit capacity.....	46
	8.7	Performance under conditional short-circuit current conditions	46
	8.8	Resistance to mechanical shock and impact.....	46
	8.9	Resistance to heat	46
	8.10	Resistance to abnormal heat and to fire	46
	8.11	Resistance to tracking	46
	8.12	Resistance to rusting.....	47
9	Tests		48
	9.1	Type tests and sequences	48
	9.2	Test conditions	49
	9.3	Test of indelibility of marking	50
	9.4	Test of reliability of terminals, current-carrying parts and connections	50
	9.5	Test of reliability of terminals for external conductors (see 3.12.15)	53
	9.6	Test of protection against electric shock.....	54
	9.7	Test of dielectric properties	55
	9.8	Test of temperature-rise	58
	9.9	28-day test	59
	9.10	Test of tripping characteristics.....	59
	9.11	Verification of electrical operational capability	60
	9.12	Conditional short-circuit tests	64
	9.13	Test of resistance to mechanical shock and impact	67
	9.14	Tests of resistance to heat	67
	9.15	Test of resistance to abnormal heat and to fire	68
	9.16	Test of resistance to tracking.....	68
	9.17	Test of resistance to rusting	69
	Annex A (normative)	Time-current zone.....	75
	Annex B (normative)	Determination of clearances and creepage distances.....	76
	Annex C (normative)	Test sequences and number of samples to be submitted for certification purposes.....	78
	Annex D (normative)	Correspondence between ISO and AWG copper conductors	81
	Annex E (normative)	Examples of terminals.....	82
	Annex F (informative)	Coordination between a CBE and a short-circuit protective device (SCPD) associated in the same circuit.....	91
	Annex G (normative)	Electromagnetic behaviour of CBEs	104
	Annex H (normative)	Correlation between nominal voltage of the supply systems and the line-to-neutral voltage relevant for determining the rated impulse voltage	106
	Annex J (normative)	Routine or statistical tests	107
	Annex K (normative)	Additional requirements for electrical performance of E-type CBEs	109
	Annex L (normative)	Additional requirements for CBEs suitable for isolation.....	110
	Bibliography.....		114

Figure 1 – Thread-forming screw	70
Figure 2 – Thread-cutting screw.....	70
Figures 3 to 6 – Test circuits for overcurrent tests	71
Figure 7 – Standard test finger.....	72
Figure 8 – Ball pressure apparatus	73
Figure 9 – Arrangements and dimensions of the electrodes for the tracking test	73
Figures 10 to 13 – Test circuits for verification of the conditional short-circuit current	74
Figures A.1 to A.4	75
Figures B.1 to B.10	77
Figure E.1 – Examples of pillar terminals	82
Figure E.2 – Examples of screw terminals and stud terminals	83
Figure E.3 – Examples of saddle terminals	84
Figure E.4 – Examples of lug terminals	84
Figure E.5 – Examples of screwless terminals with clamping means	85
Figure E.6 – Dimensions of male tabs	86
Figure E.7 – Dimensions of round dimple detents of male tabs (see figure E.6)	87
Figure E.8 – Dimensions of rectangular dimple detents of male tabs	87
Figure E.9 – Dimensions of hole detents of male tabs	87
Figure E.10 – Dimensions of male tabs	88
Figure E.11 – Dimensions of male tabs	88
Figure E.12 – Dimensions of male tabs	88
Figure E.13 – Dimensions of male tabs for two different sizes of female connectors	89
Figure E.14 – Dimensions of female connectors for male tabs	90
Figure F.1 – Thermal only CBE, backed up by thermal magnetic circuit-breaker	97
Figure F.2 – Thermal only CBE, backed up by a fuse	98
Figure F.3 – Thermal-magnetic CBE backed up by thermal-magnetic circuit-breaker	99
Figure F.4 – Hydraulic-magnetic CBE backed up by thermal-magnetic circuit-breaker	100
Figure F.5 – Thermal CBE backed up by a hydraulic-magnetic circuit-breaker	100
Figure F.6 – Energy-limiting CBE, backed up by thermal-magnetic circuit-breaker	101
Figure F.7 – Energy-limiting CBE, backed up by a fuse	102
Figure F.8 – Examples illustrating proper and improper coordination	103
 Table 1 – Minimum clearances for basic and reinforced insulation	 32
Table 2 – Minimum creepage distances	34
Table 3 – Connectable cross-sectional areas of external copper conductors for screw type and screwless terminals	36
Table 4 – Minimum distance between clamping screw and the end of conductor when fully inserted	37
Table 5 – Dimensions of tabs in millimetres – Dimensions A, B, C, D, E, F, J, M, N, P and Q	40

I.S. EN 60934:2001

60934 © IEC:2000+A1:2007+A2:2013

– 5 –

Table 6 – Dimensions of tabs in millimetres – Dimensions H, I, T, K, R, G, L, S and U	41
Table 7 – Dimensions in millimetres of combined male tabs for two different sizes of female connectors	41
Table 8 – Temperature-rise values for CBEs for different reference ambient air temperatures (T).....	43
Table 9 – Time-current operating characteristics.....	44
Table 10 – Operating limits of undervoltage and zero-voltage releases (for a.c. and d.c.)	45
Table 11 – Test conditions for electrical performance for CBEs intended for general use, including inductive circuits	47
Table 12 – Test conditions for electrical performance of CBEs used in essentially resistive circuits only	48
Table 13 – List of type tests.....	49
Table 14 – Standard cross-sections of copper conductors corresponding to the rated currents	50
Table 15 – Screw-thread diameter and applied torques.....	51
Table 16 – Insertion and withdrawal forces	52
Table 17 – Push/pull force	53
Table 18 – Pulling forces	53
Table 19 – Make-up of conductors for the test of 9.5.3.....	54
Table 20 – Test voltages.....	57
Table 21 – Impulse withstand test voltages for verification of insulation coordination	58
Table 22 – Power factor and time constant of test circuit	65
Table C.1 – Test sequences	78
Table C.2 – Number of samples for full test procedure.....	79
Table C.3 – Reduction of samples for simplified test procedure	80
Table D.1 – Correspondence between ISO and AWG conductor cross-sections	81
Table G.2.2 – Minimum EMC immunity performances of CBEs.....	105
Table H.1 – Nominal voltages and corresponding rated impulse voltages.....	106
Table L.1 – Minimum clearances for CBEs suitable for isolation, between live parts separated when the contacts are in the open position, as a function of the rated impulse withstand voltage.....	111
Table L.2 – Minimum creepage distances for CBEs suitable for isolation, between live parts separated when the contacts are in the open position.....	111
Table L.3 – Test voltages for verifying isolation across the open contacts, as a function of the rated impulse withstand voltage and the altitude where the test is carried out	113

INTERNATIONAL ELECTROTECHNICAL COMMISSION

CIRCUIT-BREAKERS FOR EQUIPMENT (CBE)

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60934 has been prepared by subcommittee 23E: Circuit-breakers and similar equipment for household use, of IEC technical committee 23: Electrical accessories.

This consolidated version of IEC 60934 consists of the third edition (2000) [documents 23E/430/FDIS and 23E/441/RVD], its amendment 1 (2007) [documents 23E/624/FDIS and 23E/627/RVD] and its amendment 2 (2013) [documents 23E/767/FDIS and 23E/774/RVD].

The technical content is therefore identical to the base edition and its amendments and has been prepared for user convenience.

It bears the edition number 3.2.

A vertical line in the margin shows where the base publication has been modified by amendments 1 and 2.

| Annexes A, B, C, D, E, G, H, J, K and L form an integral part of this standard.

Annex F is for information only.

I.S. EN 60934:2001

60934 © IEC:2000+A1:2007+A2:2013

– 7 –

In this standard, the following print types are used:

- Requirements proper: in roman type
- *Test specifications: in italic type*
- Explanatory matter: in smaller roman type.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

CIRCUIT-BREAKERS FOR EQUIPMENT (CBE)

1 Scope

This International Standard is applicable to mechanical switching devices designed as "circuit-breakers for equipment" (CBE) for household and similar applications. CBEs according to this standard are intended to provide protection to circuits within electrical equipment including its components (e.g. motors, transformers, internal wiring). This standard covers also CBEs applicable for protection of electrical equipment in case of undervoltage and/or overvoltage. This standard also covers CBEs which are suitable for isolation.

NOTE The term "equipment" includes appliances.

CBEs are not applicable for overcurrent protection of wiring installations of buildings.

CBEs according to this standard have:

- a rated voltage not exceeding 440 V a.c. (between phases) and/or d.c. not exceeding 250 V;
- a rated current not exceeding 125 A;
- a short-circuit capacity (I_{cn}) of at least $6xI_n$ (a.c. types) and $4xI_n$ (d.c.-types) but not exceeding 3 000 A.

CBEs may have a conditional short-circuit current rating in association with a specified short-circuit protective device (SCPD). A guide for coordination of a CBE associated in the same circuit with a SCPD is given in Annex F.

For CBEs having a degree of protection higher than IP20 according to IEC 60529, for use in locations where hazardous environmental conditions prevail (e.g. excessive humidity, heat or cold or deposition of dust) and in hazardous locations (e.g. where explosions are liable to occur), special constructions may be required.

This standard contains all the requirements necessary to ensure compliance with the operational characteristics required for these devices by type tests. It also contains the details relative to test requirements and methods of testing necessary to ensure reproducibility of test results.

This standard states:

- a) the characteristics of CBEs;
- b) the conditions with which CBEs shall comply, with reference to:
 - 1) their operation and behaviour in normal service;
 - 2) their operation and behaviour in case of overload;
 - 3) their operation and behaviour in case of short-circuits up to their rated short-circuit capacity;
 - 4) their dielectric properties;
- c) the tests intended for confirming that these conditions have been met and the methods to be adopted for the tests;
- d) the data to be marked on the devices;
- e) the test sequences to be carried out and the number of samples to be submitted for certification purposes (see Annex C);
- f) the routine tests to be carried out to reveal unacceptable variations in material or manufacture, likely to affect safety (see Annex J).

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-