



NSAI
Standards

Irish Standard
I.S. EN 16445:2013

Ventilation for buildings - Air diffusion - Aerodynamic testing and rating for mixed flow application: non-isothermal procedure for cold jet

I.S. EN 16445:2013

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWIFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces:

This document is based on:
EN 16445:2013

Published:
5 March, 2013

This document was published under the authority of the NSAI and comes into effect on:
5 March, 2013

ICS number:

91.140.30

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

ICS 91.140.30

English Version

Ventilation for buildings - Air diffusion - Aerodynamic testing and rating for mixed flow application: non-isothermal procedure for cold jet

Ventilation des bâtiments - Bouches d'air - Essais
aérodynamiques et étalonnage pour applications de fluides
mixtes pour les essais non-isothermes pour jet froid

Lüftung von Gebäuden - Luftverteilung - Aerodynamische
Prüfung und Bewertung von Mischstromanwendungen:
Nicht-isothermes Verfahren für einen Kaltluftstrahl

This European Standard was approved by CEN on 8 December 2012.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents	Page
Foreword.....	3
1 Scope.....	4
2 Normative references.....	4
3 Terms and definitions	4
4 Symbols (and abbreviated terms)	6
5 Requirements	7
5.1 Instrumentation	7
5.1.1 Air flow rate measurement.....	7
5.1.2 Temperature measurements.....	7
5.1.3 Velocity measurements	7
5.2 Test room and conditions.....	7
5.3 ATD isothermal characteristics	7
6 Test to measure the non isothermal air discharge characteristics of a supply ATD	8
6.1 Installation of ATD.....	8
6.2 Test procedure for horizontal cold jet.....	10
6.2.1 Test conditions.....	10
6.2.2 Preliminary conditions prior to formal measurement.....	10
6.2.3 Measurements.....	11
7 Report.....	19
7.1 Test conditions.....	19
7.2 Results.....	19
Bibliography.....	21

Foreword

This document (EN 16445:2013) has been prepared by Technical Committee CEN/TC 156 "Ventilation for buildings", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2013, and conflicting national standards shall be withdrawn at the latest by August 2013.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

According to the CEN/CENELEC Internal Regulations, the national standards organisations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

1 Scope

This European Standard specifies methods for the laboratory aerodynamic testing and rating of air terminal devices for mixed flow applications, including the specification of suitable test facilities and measurement techniques. This standard applies to laboratory testing of ATD for technical characterisation.

The standard gives only tests for the assessment of characteristics of the air terminal devices for mixed flow applications, under non-isothermal conditions with a cold jet. It does not cover the testing of isothermal or low velocity terminal devices which are covered by other published standards.

This European Standard applies to ventilation or air conditioning systems designed for the maintenance of comfort conditions for buildings. It is not applicable in the case of systems for the control of industrial or other special process environments. In the latter case however, it may be referred to if the system technology is similar to that of the above mentioned ventilation and air conditioning systems.

The principles described in this European Standard can also be used on site or in a lab for full-scale measurements.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 12238, *Ventilation for buildings — Air terminal devices — Aerodynamic testing and rating for mixed flow application*

EN 12239, *Ventilation for buildings — Air terminal devices — Aerodynamic testing and rating for displacement flow applications*

EN 13182, *Ventilation for buildings — Instrumentation requirements for air velocity measurements in ventilated spaces*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply:

3.1

supply air

air entering a supply air terminal device from an upstream duct

3.2

exhaust air

air leaving an exhaust air terminal device into a downstream duct

3.3

local measured mean air velocity

measured value of local airstream velocity as described in EN 12238

3.4

treated space

enclosure served by an air distribution system; in this standard this is the test room

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-