This is a free page sample. Access the full version online.



Irish Standard I.S. EN 15848:2010

Water conditioning equipment inside buildings - Adjustable chemical dosing systems - Requirements for performance, safety and testing

© NSAI 2010 No copying without NSAI permission except as permitted by copyright law.

I.S. EN 15848:2010

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWIFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i>	<i>This document is based o</i> EN 15848:2010		<i>hed:</i> rruary, 2010		
This document was published under the authority of the NSAI and comes into effect on: 22 March, 2010			ICS number: 13.060.20 91.140.60		
Northwood, Santry F +3 Dublin 9 E st	5318073838 F+	es: 353 1 857 6730 353 1 857 6729 standards.ie			
Údarás um Chaighdeáin Náisiúnta na hÉireann					

I.S. EN 15848:2010

EUROPEAN STANDARD NORME EUROPÉENNE

EN 15848

EUROPÄISCHE NORM

February 2010

ICS 13.060.20; 91.140.60

English Version

Water conditioning equipment inside buildings - Adjustable chemical dosing systems - Requirements for performance, safety and testing

Appareils de traitement d'eau à l'intérieur des bâtiments -Systèmes de dosage chimique ajustables - Exigences de performance, de sécurité et essais Anlagen zur Behandlung von Trinkwasser innerhalb von Gebäuden - Einstellbare Dosiersysteme - Anforderungen an Ausführung, Sicherheit und Prüfung

This European Standard was approved by CEN on 9 January 2010.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: Avenue Marnix 17, B-1000 Brussels

© 2010 CEN All rights of exploitation in any form and by any means reserved worldwide for CEN national Members.

Ref. No. EN 15848:2010: E

EN 15848:2010 (E)

I.S. EN 15848:2010

Contents

Page

Forewo	ord	3
1	Scope	4
2	Normative references	4
3	Terms and definitions	4
4 4.1	Design requirements	
4.2	Dosing system components	
4.3 4.4	Materials of construction	-
4.5	Radio interference and electrical safety	5
4.6 4.7	Accessibility	
4.8	Manual mode	
5	Performance requirements	
5.1 5.2	Chemicals	
5.3	Protection against overdosing	
5.4 5.5	Working temperature range Pressure conditions	
6 6.1	Testing	
6.2	Operating characteristics	8
6.3	Pressure test	-
7	Labelling 10	
Annex	A (normative) Installation, operation and maintenance1	1
Bibliog	raphy1	5

I.S. EN 15848:2010

Foreword

This document (EN 15848:2010) has been prepared by Technical Committee CEN/TC 164 "Water supply", the secretariat of which is held by AFNOR.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by August 2010, and conflicting national standards shall be withdrawn at the latest by August 2010.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

NOTE Products intended for use in water supply systems should comply, when existing, with national regulations and testing arrangements that ensure fitness for contact with drinking water.

On April 2006, EC Commission set up a revised mandate (M/136) asking CEN to propose harmonised product standards and support standards for test methods which could be used for assessing the fitness for contact with drinking water. In parallel, EC Commission has launched processes for a regulation of construction products (CPR) to be substituted to CP directive (89/106/EC) and for the revision of drinking water directive (98/83/EC).

If relevant, when the outputs of these processes are known, European product standards will be amended by the addition of an Annex Z under Mandate M136 which will contain formal references to the applicable requirements. Until such amendments, the current national regulations remain applicable.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

1 Scope

This European Standard specifies definitions, principles of construction (but not dimensions) and design, requirements on performance and operation as well as methods for testing the performance of adjustable chemical dosing systems for conditioning water intended for human consumption inside buildings (see [1]) which are permanently connected to the mains supply.

The concentration in the treated water of the active chemical(s) as well as of any other ingredient or minor component (including possible contaminants) should not exceed the parametric values laid down in the existing legislation in the Member States for the water intended for the human consumption, as implemented by the national authorities.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 55011, Industrial, scientific and medical (ISM) radio-frequency equipment — Electromagnetic disturbance characteristics — Limits and methods of measurement (CISPR 11:2003 + A1:2004, modified)

EN 60204-1, Safety of machinery — Electrical equipment of machines — Part 1: General requirements (IEC 60204-1:2005, modified)

EN 60335-1, Household and similar electrical appliances — Safety — Part 1: General requirements (IEC 60335-1:2001, modified)

EN 60335-2-41, Household and similar electrical appliances — Safety — Part 2-41: Particular requirements for pumps (IEC 60335-2-41:2002)

EN ISO 12100-1, Safety of machinery — Basic concepts, general principles for design — Part 1: Basic terminology, methodology (ISO 12100-1:2003)

EN ISO 12100-2, Safety of machinery — Basic concepts, general principles for design — Part 2: Technical principles (ISO 12100-2:2003)

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

adjustable dosing system

device used for the controlled addition of chemicals in concentrations that can be adjusted on the installation site

3.2

working range

range of treated water flow rates between which the dosing system provides the required accuracy of concentration of the chemicals within limits of concentration and pressure drop prescribed by the manufacturer.

NOTE The working range covers the range between the upper and lower working limits.

3.3

dosing agent

active chemical substance for conditioning water intended for human consumption



This is a free preview. Purchase the entire publication at the link below:

Product Page

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation