This is a free page sample. Access the full version online.



Irish Standard I.S. EN 13757-6:2015

Communication systems for meters - Part 6: Local Bus

 $\ensuremath{\mathbb O}$ CEN 2015 $\hfill No copying without NSAI permission except as permitted by copyright law.$

I.S. EN 13757-6:2015

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWIFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on: EN 13757-6:2015

Dublin 9

Published: 2015-12-02

W standards.ie

<i>This document was published</i> under the authority of the NSAI			ICS number:
and comes into effect on:			33.200
			35.100.10
2015-12-20			35.100.20
		NOTE: If blar	nk see CEN/CENELEC cover page
NSAI	T +353 1 807 3800		Sales:
1 Swift Square,	F +353 1 807 3838		T +353 1 857 6730
Northwood, Santry	E standards@nsai.ie		F +353 1 857 6729

Údarás um Chaighdeáin Náisiúnta na hÉireann

W NSAI.ie

National Foreword

I.S. EN 13757-6:2015 is the adopted Irish version of the European Document EN 13757-6:2015, Communication systems for meters - Part 6: Local Bus

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This is a free page sample. Access the full version online.

This page is intentionally left blank

EUROPEAN STANDARD

EN 13757-6

NORME EUROPÉENNE

EUROPÄISCHE NORM

December 2015

ICS 33.200; 35.100.10; 35.100.20

Supersedes EN 13757-6:2008

English Version

Communication systems for meters - Part 6: Local Bus

Systèmes de communication pour compteurs - Partie 6: Bus local Kommunikationssysteme für Zähler - Teil 6: Lokales Bussystem

This European Standard was approved by CEN on 27 September 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

This is a free page sample. Access the full version online. $I.S.\ EN\ 13757-6:2015$

EN 13757-6:2015 (E)

Contents

Europ	ean foreword	3
Introd	uction	4
1	Scope	5
2	Normative references	5
3	Physical Layer Specifications	5
Annex	A (informative) Schematic implementation of a meter interface	7
Bibliog	graphy	8

European foreword

This document (EN 13757-6:2015) has been prepared by Technical Committee CEN/TC 294 "Communication systems for meters", the secretariat of which is held by DIN.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by June 2016, and conflicting national standards shall be withdrawn at the latest by June 2016.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes EN 13757-6:2008.

The following significant editorial changes compared to the previous edition have been incorporated in this European Standard:

- a) update of the standards title; and
- b) update of normative references to EN 13757-2.

EN 13757 consists of the following parts, under the general title "Communication systems for meters":

- Part 1: Data exchange
- Part 2: Physical and link layer
- Part 3: Dedicated application layer
- Part 4: Wireless meter readout (Radio meter reading for operation in SRD bands)
- Part 5: Wireless M-Bus relaying
- Part 6: Local Bus

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

Introduction

This European Standard is part of a series of standards which covers communication systems for meters and remote reading of meters.

- EN 13757-1 contains generic descriptions and a communication protocol,
- EN 13757-2 contains the description of the physical and link layer of a universal twisted pair bus system (M-Bus),
- EN 13757-3 contains higher protocol layers like transport or application layer,
- EN 13757-4 specifies wireless communication and
- EN 13757-5 specifies a relaying extension of EN 13757-4.

This European Standard can be used with various link and application layers. Frequently, the application layer of EN 13757-3 (M-Bus) or the DLMS based application layer described in EN 13757-1 is used. An overview of communication systems for meters is given in EN 13757-1, which also contains further definitions.

1 Scope

This European Standard specifies the physical layer parameters of a local meter readout system ("Local Bus") for the communication with and the readout of a single meter or a small cluster of meters via a single battery powered readout device ("master") which can be connected temporarily or stationary for the communication directly to a meter (i.e. local readout) or via a fixed wiring or a small bus (i.e. remote readout).

For generic descriptions concerning communication systems for meters and remote reading of meters, refer to EN 13757-1.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13757-2, Communication systems for meters and remote reading of meters — Part 2: Physical and link layer

3 Physical Layer Specifications

The Local Bus is an alternative to the M-Bus. It is restricted to small installations (Mini installation according to EN 13757-2:2004, Annex E.6.1 type E) and optimized for special battery-driven masters. Usually the readout frequency is limited by the meter. The total cable length is limited to 50 m. The Local Bus does not support meter power supply from the bus. Note that this meter interface is not compatible with M-Bus masters according to EN 13757-2. To facilitate the meter power management, the master shall switch the bus power on (i.e. enter the master mark send state) not more than 10 s before any meter communication.

NOTE Annex A shows a possible circuit diagram for implementing such an interface.

A meter equipped with a Local Bus interface shall meet the requirements of Table 1.



This is a free preview. Purchase the entire publication at the link below:

Product Page

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation