



NSAI
Standards

Irish Standard
I.S. EN 62040-1:2008

Uninterruptible power systems (UPS) -- Part 1: General and safety requirements for UPS (IEC 62040-1:2008 (EQV) + corrigendum Aug. 2008 (EQV))

I.S. EN 62040-1:2008

Incorporating amendments/corrigenda issued since publication:

EN 62040-1:2008/A1:2013

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i> EN 62040-1-1:2003	<i>This document is based on:</i> EN 62040-1:2008 EN 62040-1-1:2003	<i>Published:</i> 27 November, 2008 16 January, 2003
This document was published under the authority of the NSAI and comes into effect on: 26 January, 2009		ICS number: 29.200
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 62040-1/A1

May 2013

ICS 29.200

English version

Uninterruptible power systems (UPS) -
Part 1: General and safety requirements for UPS
(IEC 62040-1:2008/A1:2013)

Alimentations sans interruption (ASI) -
Partie 1: Exigences générales et règles de
sécurité pour les ASI
(CEI 62040-1:2008/A1:2013)

Unterbrechungsfreie
Stromversorgungssysteme (USV) -
Teil 1: Allgemeine Anforderungen und
Sicherheitsanforderungen
(IEC 62040-1:2008/A1:2013)

This amendment A1 modifies the European Standard EN 62040-1:2008; it was approved by CENELEC on 2013-02-14. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 22H/151/FDIS, future edition 1 of IEC 62040-1:2008/A1, prepared by SC 22H, "Uninterruptible power systems (UPS)", of IEC TC 22, "Power electronic systems and equipment" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62040-1:2008/A1:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2013-11-17
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-02-14

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62040-1:2008/A1:2013 was approved by CENELEC as a European Standard without any modification.

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

Addition to Annex ZA of EN 62040-1:2008:

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61439-1	2011	Low-voltage switchgear and controlgear assemblies - Part 1: General rules	EN 61439-1	2011

This page is intentionally left BLANK.

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 62040-1

November 2008

ICS 29.200

Supersedes EN 62040-1-1:2003 and EN 62040-1-2:2003
Incorporates corrigendum February 2009

English version

**Uninterruptible power systems (UPS) -
Part 1: General and safety requirements for UPS
(IEC 62040-1:2008 + corrigendum September 2008)**

Alimentations sans interruption (ASI) -
Partie 1: Exigences générales
et règles de sécurité pour les ASI
(CEI 62040-1:2008 +
corrigendum septembre 2008)

Unterbrechungsfreie
Stromversorgungssysteme (USV) -
Teil 1: Allgemeine Anforderungen
und Sicherheitsanforderungen
(IEC 62040-1:2008 +
Corrigendum September 2008)

This European Standard was approved by CENELEC on 2008-09-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

I.S. EN 62040-1:2008

EN 62040-1:2008

- 2 -

Foreword

The text of document 22H/104/FDIS, future edition 1 of IEC 62040-1, prepared by SC 22H, Uninterruptible power systems (UPS), of IEC TC 22, Power electronic systems and equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 62040-1 on 2008-09-01.

This European Standard supersedes EN 62040-1-1:2003 + corrigendum August 2004 and EN 62040-1-2:2003 + corrigendum August 2004.

EN 62040-1:2008 merges all requirements of EN 62040-1-1:2003 and EN 62040-1-2:2003, with the addition of the following:

- update of normative references including EN 60950-1 as Reference Document (RD);
- harmonization and alignment with current world recognized best practices;
- enhancement of backfeed protection, definition of ground-fault, revision of temperature rise tables and of hydrogen concentration in battery compartments.

This standard is to be used in conjunction with EN 60950-1:2006 which is referred to in this standard as "RD".

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2009-06-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2011-09-01

In this standard, the following print types are used:

- requirements proper and normative annexes: in roman type;
- compliance statements and test specifications: *in italic type*;
- notes and other informative matter: in smaller roman type;
- normative conditions within tables: in smaller roman type;
- terms that are defined in Clause 3: **bold**.

Annex ZA has been added by CENELEC.

The contents of the corrigendum of February 2009 have been included in this copy.

Endorsement notice

The text of the International Standard IEC 62040-1:2008 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60439-1	NOTE Harmonized as EN 60439-1:1999 (not modified).
IEC 60925	NOTE Harmonized as EN 60925:1991 (not modified).
IEC 60990	NOTE Harmonized as EN 60990:1999 (not modified).
IEC 61347	NOTE Harmonized in EN 61347 series (partially modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60364-4-42	- ¹⁾	Electrical installations of buildings - Part 4-42: Protection for safety - Protection against thermal effects	-	-
IEC 60417	Data- base	Graphical symbols for use on equipment	-	-
IEC 60529	- ¹⁾	Degrees of protection provided by enclosures (IP Code)	EN 60529 + corr. May	1991 ²⁾ 1993
IEC 60664	Series	Insulation coordination for equipment within low-voltage systems	EN 60664	Series
IEC/TR 60755	- ¹⁾	General requirements for residual current operated protective devices	-	-
IEC 60950-1 (mod)	2005	Information technology equipment - Safety - Part 1: General requirements	EN 60950-1	2006
IEC 61000-2-2	- ¹⁾	Electromagnetic compatibility (EMC) - Part 2-2: Environment - Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems	EN 61000-2-2	2002 ²⁾
IEC 61008-1 (mod)	- ¹⁾	Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's) - Part 1: General rules	EN 61008-1 + A11	2004 ²⁾ 2007
IEC 61009-1 (mod)	- ¹⁾	Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBO's) - Part 1: General rules	EN 61009-1 + corr. July + A11	2004 ²⁾ 2006 2008
IEC 62040-2	2005	Uninterruptible power systems (UPS) - Part 2: Electromagnetic compatibility (EMC) requirements	EN 62040-2 + corr. November	2006 2006
IEC 62040-3 (mod)	1999	Uninterruptible power systems (UPS) - Part 3: Method of specifying the performance and test requirements	EN 62040-3	2001

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

This page is intentionally left BLANK.

CONTENTS

FOREWORD.....	6
INTRODUCTION TO THE AMENDMENT	8
1 Scope and specific applications.....	9
1.1 Scope.....	9
1.2 Specific applications.....	9
2 Normative references	10
3 Terms and definitions	11
3.1 General definitions	11
3.2 UPS electrical ratings.....	12
3.3 Load types	13
3.4 Connection to the supply	13
3.5 Circuits and circuit characteristics	13
3.6 Insulation	13
3.7 Equipment mobility.....	13
3.8 Insulation classes of UPS.....	13
3.9 Earth fault	14
3.10 Enclosures	14
3.11 Accessibility	14
3.12 Components.....	14
3.13 Power distribution.....	14
3.14 Flammability.....	14
3.15 Miscellaneous	14
3.16 Clearances and creepage distances	14
3.17 Telecommunication networks	14
4 General conditions for tests.....	14
4.1 Introduction	14
4.2 Type test.....	14
4.3 Operating parameters for tests	15
4.4 UPS loading during tests	15
4.5 Components.....	15
4.6 Power interfaces	16
4.7 Markings and instructions.....	16
4.7.1 General	16
4.7.2 Power rating.....	16
4.7.3 Safety instructions	17
4.7.4 Main voltage adjustment.....	18
4.7.5 Power outlets	19
4.7.6 Fuses	19
4.7.7 Wiring terminals	19
4.7.8 Battery terminals	19
4.7.9 Controls and indicators.....	19
4.7.10 Isolation of multiple power sources	19
4.7.11 IT power systems	19
4.7.12 Protection in building installation	19
4.7.13 High leakage current	20

I.S. EN 62040-1:2008

62040-1 © IEC:2008+A1:2013

– 3 –

4.7.14	Thermostats and other regulating devices	20
4.7.15	Language	20
4.7.16	Durability of markings	20
4.7.17	Removable parts	20
4.7.18	Replaceable batteries	20
4.7.19	Operator access with a tool	20
4.7.20	Battery	20
4.7.21	Installation instructions	21
5	Fundamental design requirements	22
5.1	Protection against electric shock and energy hazards	22
5.1.1	Protection for UPS intended to be used in operator access areas	22
5.1.2	Protection for UPS intended to be used in service access areas	22
5.1.3	Protection for UPS intended to be used in restricted access areas	23
5.1.4	Backfeed protection	23
5.1.5	Emergency switching (disconnect) device	24
5.2	Requirements for auxiliary circuits	24
5.2.1	Safety extra low voltage circuits – SELV	24
5.2.2	Telephone network voltage circuits – TNV	24
5.2.3	Limited current circuits	24
5.2.4	External signalling circuits	24
5.2.5	Limited power source	24
5.3	Protective earthing and bonding	24
5.3.1	General	24
5.3.2	Protective earthing	24
5.3.3	Protective bonding	25
5.4	AC and d.c. power isolation	25
5.4.1	General	25
5.4.2	Disconnect devices	25
5.5	Overcurrent and earth fault protection	26
5.5.1	General	26
5.5.2	Basic requirements	26
5.5.3	Battery circuit protection	26
5.5.4	Short-time withstand current	27
5.6	Protection of personnel – Safety interlocks	29
5.6.1	Operator protection	29
5.6.2	Service person protection	29
5.7	Clearances, creepage distances and distances through insulation	31
6	Wiring, connections and supply	31
6.1	General	31
6.1.1	Introduction	31
6.1.2	Dimensions and ratings of busbars and insulated conductors	31
6.2	Connection to power	32
6.2.1	General provisions for connection to power	32
6.2.2	Means of connection	32
6.3	Wiring terminals for external power conductors	32
7	Physical requirements	32
7.1	Enclosure	32
7.2	Stability	33
7.3	Mechanical strength	33

7.4	Construction details.....	33
7.4.1	Introduction	33
7.4.2	Openings.....	33
7.4.3	Gas concentration	34
7.4.4	Equipment movement.....	34
7.5	Resistance to fire	34
7.6	Battery location	34
7.6.1	Battery location and installation	34
7.6.2	Accessibility and maintainability	34
7.6.3	Distance	35
7.6.4	Case insulation.....	35
7.6.5	Wiring.....	35
7.6.6	Electrolyte spillage	35
7.6.7	Ventilation	35
7.6.8	Charging voltages.....	36
7.7	Temperature rise.....	36
8	Electrical requirements and simulated abnormal conditions	37
8.1	General provisions for earth leakage	37
8.2	Electric strength	37
8.3	Abnormal operating and fault conditions.....	37
8.3.1	General	37
8.3.2	Simulation of faults.....	37
8.3.3	Conditions for tests.....	38
9	Connection to telecommunication networks	38
	Annex A (normative) Tests for resistance to heat and fire	39
	Annex B (normative) Motor tests under abnormal conditions	40
	Annex C (normative) Transformers	41
	Annex D (normative) Measuring instruments for touch current tests	42
	Annex E (normative) Temperature rise of a winding	43
	Annex F (normative) Measurements of clearances and creepage distances	44
	Annex G (normative) Alternative method for determining minimum clearances	45
	Annex H (informative) Guidance on protection against ingress of water and foreign objects.....	46
	Annex I (normative) Backfeed protection test.....	48
	Annex J (informative) Table of electrochemical potentials	51
	Annex K (normative) Thermal controls	52
	Annex L (normative) Reference loads	53
	Annex M (normative) Ventilation of battery compartments.....	57
	Annex N (normative) Minimum and maximum cross-sections of copper conductors suitable for connection (see 6.3).....	60
	Annex O (informative) Guidance for disconnection of batteries during shipment.....	61
	Annex P (informative) Short-time withstand current test procedure – Guidance and typical values.....	63
	Bibliography.....	65

I.S. EN 62040-1:2008

62040-1 © IEC:2008+A1:2013

– 5 –

Figure I.1 – Test circuit for load-induced change of reference potential – single-phase output	49
Figure I.2 – Test circuit for load-induced change of reference potential – three-phase output	49
Figure O.1 – Precautionary label for products shipped with the battery disconnected	61
Figure O.2 – Precautionary label for products shipped with the battery connected	62
Figure P.1 – Test circuit for UPS short-time withstand current.....	63
 Table 1 – Temperature limits	 36
Table 2 – Permitted temperature limits for magnetic windings at the end of stored energy mode of operation	36
Table 3 – Short time withstand current.....	28
Table H.1 – Degrees of protection against foreign objects indicated by the first characteristic numeral	46
Table H.2 – Degrees of protection against water indicated by the second characteristic numeral	47
Table N.1 – Conductor cross-sections (extract from IEC 60439-1)	60

INTERNATIONAL ELECTROTECHNICAL COMMISSION

UNINTERRUPTIBLE POWER SYSTEMS (UPS) –

Part 1: General and safety requirements for UPS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of IEC 62040-1 consists of the first edition (2008) [documents 22H/104/FDIS and 22H/106/RVD], its amendment 1 (2013) [documents 22H/151/FDIS and 22H/155/RVD] and its corrigendum of September 2008. It bears the edition number 1.1.

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience. A vertical line in the margin shows where the base publication has been modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through.

I.S. EN 62040-1:2008

62040-1 © IEC:2008+A1:2013

– 7 –

International Standard IEC 62040-1 has been prepared by subcommittee 22H: Uninterruptible power systems (UPS), of IEC technical committee 22: Power electronic systems and equipment.

This standard cancels and replaces the first edition of IEC 62040-1-1, published in 2004 and IEC 62040-1-2, published in 2004 and constitutes a technical revision. This standard merges all requirements of previous IEC 62040-1-1 and IEC 62040-1-2, with the addition of the following:

- update of normative references including IEC 60950-1 as Reference Document (RD);
- harmonization and alignment with current world recognized best practices;
- enhancement of backfeed protection, definition of ground-fault, revision of temperature rise tables and of hydrogen concentration in battery compartments;
- **Amendment 1 introduces short-time withstand current requirements when a short-circuit is applied at the output of the UPS (5.5.4).**

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

It is to be used with IEC 60950-1, Edition 2.0, which is referred to in this standard as "RD".

In this standard, the following print types are used:

- requirements proper and normative annexes: in roman type;
- compliance statements and test specifications: *in italic type*;
- notes and other informative matter: in smaller roman type;
- normative conditions within tables: in smaller roman type;
- terms that are defined in Clause 3: **bold**.

A list of all parts of the IEC 62040 series, under the general title: *Uninterruptible power systems (UPS)*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION TO THE AMENDMENT

This amendment determines the short-time withstand current test requirements for the purpose of verifying the safety of the **UPS** when a short circuit is applied across the output terminals under prescribed modes of operation wherein the output power is delivered by the a.c. input through a **low impedance path**.

UNINTERRUPTIBLE POWER SYSTEMS (UPS) –

Part 1: General and safety requirements for UPS

1 Scope and specific applications

1.1 Scope

This part of IEC 62040 applies to **uninterruptible power systems (UPS)** with an electrical energy storage device in the d.c. link. It is used with IEC 60950-1, which is referred to in this standard as "RD" (reference document).

NOTE **UPS** applications generally make use of a chemical battery as the energy storage device. Alternative devices may be suitable, and as such, where "battery" appears in the text of this standard, where applicable, this may be understood as "energy storage device".

When a clause is referred to by the phrase "The definitions or the provisions of item/RD apply", this phrase is intended to mean that the definitions or provisions in that clause of IEC 60950-1 apply, except any which are clearly inapplicable to **uninterruptible power systems**. National requirements additional to those in IEC 60950-1 apply and are found as notes under relevant clauses of the RD.

The primary function of the **UPS** covered by this standard is to ensure continuity of an alternating power source. The **UPS** may also serve to improve the quality of the power source by keeping it within specified characteristics.

This standard is applicable to **UPS** which are movable, stationary, fixed or for building-in, for use in low-voltage distribution systems and intended to be installed in any **operator** accessible area or in **restricted access locations** as applicable. It specifies requirements to ensure safety for the **operator** and layman who may come into contact with the equipment and, where specifically stated, for the **service person**.

This standard is intended to ensure the safety of installed **UPS**, both as a single **UPS** unit or as a system of interconnected **UPS** units, subject to installing, operating and maintaining the **UPS** in the manner prescribed by the manufacturer.

This standard does not cover **UPS** based on rotating machines.

Electromagnetic compatibility (EMC) requirements and definitions are given in IEC 62040-2.

1.2 Specific applications

Even if this standard does not cover all types of **UPS**, it may be taken as a guide for such equipment. Requirements additional to those specified in this standard may be necessary for specific applications, e.g. related to **UPS** that operate:

- while exposed to extremes of temperature; to excessive dust, moisture, or vibration; to flammable gases; to corrosive or to explosive atmospheres;
- where ingress of water and foreign objects are possible;

NOTE 1 Annex H provides guidance on such requirements and on relevant testing.

- in vehicles, on board ships or aircraft, in tropical countries, or at elevations greater than 1 000 m;

NOTE 2 Guidance for performance of **UPS** operating at elevations greater than 1 000 m is provided in 4.1.1 of IEC 62040-3.

- with trapezoidal output waveforms and long run times (greater than 30 min);
NOTE 3 In addition to complying with 5.3.1.2 of IEC 62040-3, voltage distortion tests for the purpose of load compatibility should also be performed.
- subject to transient overvoltages exceeding those of overvoltage category II according to IEC 60664;
NOTE 4 Subclause G.2.1/RD provides guidance for additional protection against transient overvoltages at the mains supply to the **UPS**. Where such additional protection is an integral part of the equipment insulation requirements, creepage distances and clearance distances from the mains through to the load side of the additional protection may be judged as category III or IV as required. All further downstream insulation requirements, creepage distances, and clearance distances on the load side of the additional protection may be judged as category I or II as required.
- in electromedical applications with the **UPS** located within 1,5 m of the patient contact area;
- in systems classified as emergency power systems by an authority having jurisdiction.

NOTE 5 Additional requirements may also apply in accordance with local regulations.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-4-42, *Electrical installations of buildings – Part 4-42: Protection for safety – Protection against thermal effects*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*

IEC 60664 (all parts), *Insulation coordination for equipment within low-voltage systems*

IEC 60755, *General requirements for residual current operated protective devices*

IEC 60950-1:2005, *Information technology equipment – Safety – Part 1: General requirements*

IEC 61000-2-2, *Electromagnetic compatibility (EMC) – Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signaling in public low-voltage power supply systems*

IEC 61008-1, *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs) – Part 1: General rules*

IEC 61009-1, *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs) – Part 1: General rules*

IEC 61439-1:2011, *Low-voltage switchgear and controlgear assemblies – Part 1: General rules*

IEC 62040-2:2005, *Uninterruptible power systems (UPS) – Part 2: Electromagnetic compatibility (EMC) requirements*

IEC 62040-3:1999, *Uninterruptible power systems (UPS) – Part 3: Method of specifying the performance and test requirements*

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-