



NSAI
Standards

Standard Recommendation
S.R. CR 13902:2000

Test methods for determining the water/cement ratio of fresh concrete

S.R. CR 13902:2000

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces:

This document is based on:
CR 13902:2000

Published:
24 May, 2000

This document was published under the authority of the NSAI and comes into effect on:
24 September, 2011

ICS number:
91.100.30

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

ICS

English version

**Test methods for determining the water/cement ratio of fresh
concrete**

This CEN Report was approved by CEN on 10 April 2000. It has been drawn up by the Technical Committee CEN/TC 104.

CEN members are the national standards bodies of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Central Secretariat: rue de Stassart, 36 B-1050 Brussels

Contents

	Page
1 Introduction.....	2
1.1 General.....	2
1.2 Definitions in pr EN 206-1	2
1.3 Possible constituents of cements in pr EN 197-1	3
1.4 Points of significance for the determination of water/cement ratio	3
2 Available test methods:.....	3
2.1 General.....	3
2.2 Water content	3
2.3 Cement content	4
2.3.1 Methods relying on particle size	4
2.3.2 Chemical methods	4
3 Results of precision tests.	5
3.1 Study at CUR, ⁽⁷⁾ Netherlands.....	5
3.2 Study at the University of Dundee ⁽⁸⁾ , UK.....	5
3.3 Conclusions from experience in the Netherlands and the U.K.....	6
4 Overall conclusions.....	6
5 Bibliographie.....	7
5.1 European Standards.....	7
5.2 References	7

1 Introduction

1.1 General

In prEN 206-1, Concrete - Performance, production and conformity, there is a statement, in clause 5.2.2.2 Cement content and water/cement ratio, that if required, water/cement ratio may be determined by an agreed test method. This Technical Report reviews the test methods which are available for this purpose.

Before proceeding further, it is important to consider the definition of relevant terms in pr EN 206-1 and the possible constituents of cement listed in pr EN 197-1, Composition, specifications and conformity criteria for common cements.

1.2 Definitions in pr EN 206-1

Cl. 3.27 Cement (hydraulic binder): "A finely ground inorganic material which, when mixed with water, forms a paste which sets and hardens by means of hydration reaction and processes and which, after hardening, retains its strength and stability even under water".

Cl. 3.28 Effective water content: "The difference between the total water present in the fresh concrete and the water absorbed by the aggregate.

The total water is the added water plus water already contained in the aggregates and on the surface of the aggregates plus water in the admixtures and in additions used in the form of a slurry and water from any added ice or steam heating".

Cl. 3.29 Water/cement ratio: "Ratio of the effective water content to cement content by mass in the fresh concrete".

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-