



NSAI
Standards

Irish Standard
I.S. EN 54-2:1999

Fire detection and fire alarm systems - Part 2: Control and indicating equipment

© CEN 2006

No copying without NSAI permission except as permitted by copyright law.

I.S. EN 54-2:1999

Incorporating amendments/corrigenda issued since publication:

EN 54-2:1997/A1:2006

EN 54-2:1997/AC:1999

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 54-2:1997

EN 54-2:1997

Published:

1 January, 2006

24 April, 1998

This document was published
under the authority of the NSAI
and comes into effect on:
1 January, 2006

ICS number:
13.220.20

NSAI

1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:

T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

I.S. EN 54-2:1999

EUROPEAN STANDARD

EN 54-2:1997/A1

NORME EUROPÉENNE

EUROPÄISCHE NORM

October 2006

ICS 13.220.20

English Version

Fire detection and fire alarm systems - Part 2: Control and indicating equipment

Systèmes de détection et d'alarme incendie - Partie 2:
Équipement de contrôle et de signalisation

Brandmeldeanlagen - Teil 2: Brandmelderzentralen

This amendment A1 modifies the European Standard EN 54-2:1997; it was approved by CEN on 27 April 2006.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for inclusion of this amendment into the relevant national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CEN member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the Central Secretariat has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPÄISCHES KOMITEE FÜR NORMUNG

Management Centre: rue de Stassart, 36 B-1050 Brussels

Contents

Page

Foreword.....	4
Foreword.....	5
2 Normative references	5
3 Definitions and abbreviations	5
5 General requirements for indications.....	8
7 The fire alarm condition	8
7.5 Other indications during the fire alarm condition	9
7.8 Output to fire alarm devices (option with requirements – see also 8.2.5 a) and 9.4.2 a))	9
7.9 Control of fire alarm routing equipment (options with requirements)	10
7.9.1 Output to fire alarm routing equipment (option with requirements – see also 8.2.5 b) and 9.4.2 b))	10
7.9.2 Alarm confirmation input from fire alarm routing equipment (option with requirements)	10
7.10 Outputs to fire protection equipment (options with requirements)	10
7.10.1 Output type A (option with requirement – see also 8.2.4 f) and 9.4.1 b))	10
7.10.2 Output type B (option with requirement – see also 8.2.4 f) and 9.4.1 b))	10
7.10.3 Output type C (option with requirement – see also 8.2.4 f) and 9.4.1 b))	10
7.10.4 Fault monitoring of fire protection equipment (option with requirement – see also 8.2.4 f))	10
7.11 Delays to outputs (option with requirements; see also Annex E)	10
7.12 Dependencies on more than one alarm signal (options with requirement)	11
7.12.1 Type A dependency (option with requirement)	11
7.12.2 Type B dependency (option with requirement)	12
7.12.3 Type C dependency (option with requirement)	12
8 Fault warning condition (see also Annex F)	12
8.2 Indication of faults	13
8.4 Total loss of the power supply (option with requirements)	14
8.8 Fault output	14
8.9 Output to fault warning routing equipment (option with requirements - see also 8.2.4.g) and 9.4.1.c))	14
9 Disabled condition	14
10 Test condition (option with requirements).....	15
10.3 Indication of zones in the test state	15
11 Standardized input/output interface (option with requirements – see also Annex G)	16
12 Design requirements	16
13 Additional design requirements for software controlled control and indicating equipment	18
13.4 Program monitoring (see also Annex I)	18
13.5 The storage of programs and data (see also Annex I)	19
13.6 The monitoring of memory contents	19
14 Marking	19
15 Tests.....	20
15.1.5 Provision for tests	20
15.3 Environmental tests	20
15.3.1 General.....	20
15.3.2 Tests for one specimen.....	21
15.3.3 Tests for more than one specimen	21
15.8 Electromagnetic Compatibility (EMC), Immunity tests (operational)	22

Annex A (informative) Explanation of access levels	25
Annex B (informative) Optional functions with requirements and alternatives	26
Annex E (informative) Delays to outputs	27
Annex H (informative) Integrity of transmission paths	29
Annex I (informative) Design requirements for software controlled control and indicating equipment.....	30
Bibliography.....	40

Foreword

This document (EN 54-2:1997/A1:2006) has been prepared by Technical Committee CEN/TC 72 “Fire detection and fire alarm systems”, the secretariat of which is held by BSI.

This Amendment to the European Standard EN 54-2:1997 shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 2007, and conflicting national standards shall be withdrawn at the latest by December 2007.

This document has been prepared under a mandate given to CEN by the European Commission and the European Free Trade Association, and supports essential requirements of EU Directive(s).

For relationship with EU Directive(s), see informative Annex ZA, which is an integral part of this document.

Amendment 1 to this standard improves the additional requirements for software controlled equipment and makes a number of miscellaneous changes, to correct errors and better reflect the current state of the art. It also replaces the descriptions of the individual electromagnetic compatibility immunity tests with a reference to the EMC Product Family Standard EN 50130-4, makes editorial and technical changes to generally improve clarity, and updates the normative references.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Cyprus, Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and United Kingdom.

Foreword

Replace Date of Withdrawal to read

December 2007

2 Normative references

Clause 2: Delete the existing text and substitute

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 54-1:1996, *Fire detection and fire alarm systems — Part 1: Introduction*

EN 54-4:1997, *Fire detection and fire alarm systems — Part 4: Power supply equipment*

EN 54-7:2000, *Fire detection and fire alarm systems - Part 7: Smoke detectors - Point detectors using scattered light, transmitted light or ionization*

EN 50130-4:1995, *Alarm systems — Part 4: Electromagnetic compatibility — Product family standard: Immunity requirements for components of fire, intruder and social alarm systems*

EN 60068-1:1994, *Environmental testing - Part 1: General and guidance (IEC 60068-1:1988 + Corrigendum 1988 + A1:1992)*

EN 60068-2-1:1993, *Environmental testing; part 2: tests; tests A: cold (IEC 60068-2-1:1990)*

EN 60068-2-6:1995, *Environmental testing - Part 2: Tests - Tests Fc: Vibration (sinusoidal) (IEC 60068-2-6:1995 + Corrigendum 1995)*

EN 60068-2-47:2005, *Environmental testing - Part 2-47: Test Mounting of specimens for vibration, impact and similar dynamic tests (IEC 60068-2-47:2005)*

EN 60068-2-75:1997, *Environmental testing - Part 2: Tests - Test Eh: Hammer tests (IEC 60068-2-75:1997)*

EN 60068-2-78:2001, *Environmental testing — Part 2-78: Tests, Test Cab: Damp heat, steady state (IEC 60068-2-78:2001)*

EN 60529:1991, *Degrees of protection provided by enclosures (IP code) (IEC 60529:1989)*

EN 60721-3-3:1995, *Classification of environmental conditions - Part 3: Classification of groups of environmental parameters and their severities - Section 3: Stationary use at weatherprotected locations (IEC 60721-3-3:1994)*

3 Definitions and abbreviations

Delete 3.1.1 until 3.1.22 and substitute

3.1.1

Deleted (numbering kept)

I.S. EN 54-2:1999

EUROPEAN STANDARD

EN 54-2:1997/AC

NORME EUROPÉENNE

February 1999

EUROPÄISCHE NORM

Février 1999

Februar 1999

English version
Version Française
Deutsche Fassung

**Fire detection and fire alarm systems - Part 2: Control and indicating
equipment**

**Systèmes de détection et d'alarme incendie
- Partie 2: Equipement de contrôle et de
signalisation**

**Brandmeldeanlagen - Teil 2:
Brandmelderzentralen**

This corrigendum becomes effective on 25 February 1999 for incorporation in the official English version of the EN.

Ce corrigendum prendra effet le 25 février 1999 pour incorporation dans la version anglaise officielle de l'EN.

Die Berichtigung tritt am 25. Februar 1999 zur Einarbeitung die offizielle Englische Fassung der EN in Kraft.



EUROPEAN COMMITTEE FOR STANDARDIZATION
COMITÉ EUROPÉEN DE NORMALISATION
EUROPAISCHES KOMITEE FÜR NORMUNG

Central Secretariat: rue de Stassart, 36 B-1050 Brussels

Contents

Foreword	5
Introduction	5
1. Scope	5
2. Normative references	6
3. Definitions and abbreviations	7
3.1. Definitions	7
3.2. Abbreviations	9
4. General requirements	9
5. General requirements for indications	9
5.1. Display of functional conditions	9
5.2. Display of indications	10
5.3. Indications on alphanumeric displays	10
5.4. Indication of the supply of power	10
5.5. Audible indications	10
5.6. Additional indications	10
6. The quiescent condition	11
7. The fire alarm condition	11
7.1. Reception and processing of fire signals (see also annex C)	11
7.2 Indication of the fire alarm condition	12
7.3 Indication of the zones in alarm (see also annex D)	12
7.4 Audible indication	12
7.5 Other indications during the fire alarm condition	13
7.6 Reset from the fire alarm condition	13
7.7 Output of the fire alarm condition	13
7.8 Output to fire alarm devices (option with requirements -see also 8.2.5.a) and 9.4.2.a))	13
7.9 Output to fire alarm routing equipment (option with requirements - see also 8.2.5.b) and 9.4.2.b))	14
7.10 Output to fire protection equipment (option with requirements - see also 8.2.4.f) and 9.4.1.b))	14
7.11 Delays to outputs (option with requirements - see also 9.4.2.c) and annex E)	14
7.12 Co-incidence detection (option with requirements)	14
7.13 Alarm counter (option with requirements)	15
8 Fault warning condition (see also annex F)	15
8.1 Reception and processing of fault signals	15
8.2 Indication of faults in specified functions	16
8.3 Fault signals from points (option with requirements)	17
8.4 Total loss of the power supply (option with requirements)	17
8.5 System fault	18
8.6 Audible indication	18
8.7 Reset of fault indications	18
8.8 Fault output	18

8.9 Output to fault warning routing equipment (option with requirements - see also 9.4.1.c))	18
9 Disabled condition	19
9.1 General requirements	19
9.2 Indication of the disabled condition	19
9.3 Indication of specific disablements	19
9.4 Disablements and their indication	19
9.5 Disablement of addressable points (option with requirements)	20
10 Test condition (option with requirements)	20
10.1 General requirements	20
10.2 Indication of the test condition	21
10.3 Indication of zones in the test state	21
11 Standardized input/output interface (option with requirements - see also annex G)	21
12 Design requirements	22
12.1 General requirements and manufacturer's declarations	22
12.2 Documentation	23
12.3 Mechanical design requirements	24
12.4 Electrical and other design requirements	24
12.5 Integrity of transmission paths (see also annex H)	25
12.6 Accessibility of indications and controls (see also annex A)	25
12.7 Indications by means of light emitting indicators	26
12.8 Indications on alphanumeric displays	26
12.9 Colours of indications	27
12.10 Audible indications	27
12.11 Testing of indicators	28
13 Additional design requirements for software controlled control and indicating equipments	28
13.1 General requirements and manufacturer's declarations	28
13.2 Software documentation	28
13.3 Software design	29
13.4 Program monitoring (see also annex J)	29
13.5 The storage of programs and data (see also annex J)	30
13.6 The monitoring of memory contents	30
13.7 Operation of the c.i.e in the event of a system fault	30
14 Marking	31
15 Tests	31
15.1 General	31
15.2 Functional test	32
15.3 Environmental tests	33
15.4 Cold (operational)	35
15.5 Damp heat, steady state (operational)	36
15.6 Impact (operational)	38
15.7 Vibration, sinusoidal (operational)	40
15.8 Electrostatic discharges (operational)	42
15.9 Radiated electromagnetic interference (operational)	44
15.10 Voltage transients - fast transient bursts (operational)	45

I.S. EN 54-2:1999

Page 4

EN 54-2:1997/AC:1999

15.11 Voltage transients - slow high energy transients (operational)	47
15.12 Mains voltage dips and interruptions (operational)	50
15.13 Supply voltage variation (operational)	52
15.14 Damp heat, steady state (endurance)	53
15.15 Vibration, sinusoidal (endurance)	54
Annex A (informative) Explanation of access levels	55
Annex B (informative) Optional functions with requirements and alternatives	57
Annex C (informative)	59
Processing of signals from fire detectors	59
Annex D (informative) Explanation of zones and the zonal indication of fire alarms	60
Annex E (informative) Delays to outputs	61
Annex F (informative) Fault recognition and indication	62
Annex G (informative) Standardized input/output interface for the connection of ancillary equipment (e.g. a fire brigade panel)	63
Annex H (informative) Integrity of transmission paths	64
Annex J (informative) Design requirements for software controlled control and indicating equipments	65

Foreword

This European Standard has been prepared by the Technical Committee CEN/TC 72 “Fire detection and fire alarm systems”, the secretariat of which is held by BSI.

This standard has been prepared in co-operation with the CEA (Comité Européen des Assurances) and with EURALARM (Association of European Manufacturers of Fire and Intruder Alarm Systems).

EN 54 is published in a series of parts. Information on the relationship between this European Standard and other standards of the EN 54 series is given in annex A of EN 54-1.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by April 1998, and conflicting national standards shall be withdrawn at the latest by April 1999. In addition, a further 36 months shall be allowed for certification purposes for equipment conforming to the national standard.

According to the CEN/CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and the United Kingdom.

Introduction

This part of the European Standard EN 54 is drafted on the basis of mandatory functions which are to be provided on all control and indicating equipments, and optional functions (with requirements) which may be provided. It is intended that the options be used for specific applications, as recommended in application guidelines.

Each optional function is included as a separate entity, with its own set of associated requirements, in order to permit control and indicating equipments with many different combinations of functions to comply with this European Standard.

Other functions associated with fire detection and fire alarm may also be provided, even if not specified in this European Standard.

1. Scope

This European Standard specifies requirements, methods of test, and performance criteria for control and indicating equipment (see item B of figure 1 of EN 54-1) for use in fire detection and fire alarm systems installed in buildings.

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-