

Irish Standard I.S. EN 933-8:2012+A1:2015

Tests for geometrical properties of aggregates - Part 8: Assessment of fines -Sand equivalent test

© CEN 2015 No copying without NSAI permission except as permitted by copyright law.

#### I.S. EN 933-8:2012+A1:2015

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWIFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

*NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.* 

*This document is based on:* EN 933-8:2012+A1:2015 *Published:* 2015-05-13

This document was published		ICS number:	
and comes into effect on:		91.100.15	
2015-05-30			
		NOTE: If blank see CEN/CENELEC cover page	
NSAI	T +353 1	1 807 3800 Sales:	
1 Swift Square,	F +353 1	1 807 3838 T +353 1 857 6730	
Northwood, Santry	E standa	ards@nsai.ie F +353 1 857 6729	
Dublin 9	W NSAI.i	.ie W standards.ie	
Úda	rás um Cha	aighdeáin Náisiúnta na hÉireann	

# EUROPEAN STANDARD

# EN 933-8:2012+A1

# NORME EUROPÉENNE

# EUROPÄISCHE NORM

May 2015

ICS 91.100.15

Supersedes EN 933-8:2012

**English Version** 

# Tests for geometrical properties of aggregates - Part 8: Assessment of fines - Sand equivalent test

Essais pour déterminer les caractéristiques géométriques des granulats - Partie 8 : Évaluation des fines - Équivalent de sable Prüfverfahren für geometrische Eigenschaften von Gesteinskörnungen - Teil 8: Beurteilung von Feinanteilen -Sandäquivalent-Verfahren

This European Standard was approved by CEN on 6 November 2011 and includes Amendment 1 approved by CEN on 20 April 2015.

CEN members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration. Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CEN member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CEN member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CEN members are the national standards bodies of Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and United Kingdom.



EUROPEAN COMMITTEE FOR STANDARDIZATION COMITÉ EUROPÉEN DE NORMALISATION EUROPÄISCHES KOMITEE FÜR NORMUNG

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Ref. No. EN 933-8:2012+A1:2015 E

# This is a free page sample. Access the full version online. I.S. EN 933-8:2012+A1:2015 $\label{eq:sample}$

# EN 933-8:2012+A1:2015 (E)

# Contents

Forewo	ord	3
1	Scope	5
2	Normative references	5
3	Terms and definitions	5
4	Principle	6
5	Reagents	6
6	Apparatus	6
7 7.1 7.2 7.3	Preparation of test specimens1 General	2  2  2
8 8.1 8.2 8.3 8.4 8.5	Procedure	3  3  4  4
9	Calculation and expression of results1	6
10 10.1 10.2	Test report	7  7  7
Annex	A (normative) Procedure for the determination of the sand equivalent value of the 0/4 mm fraction1	8
Annex	B (informative) Example of a test data sheet1	9

# Foreword

This document (EN 933-8:2012+A1:2015) has been prepared by Technical Committee CEN/TC 154 "Aggregates", the secretariat of which is held by BSI.

This European Standard shall be given the status of a national standard, either by publication of an identical text or by endorsement, at the latest by November 2015, and conflicting national standards shall be withdrawn at the latest by November 2015.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN [and/or CENELEC] shall not be held responsible for identifying any or all such patent rights.

This document supersedes  $\mathbb{A}$  EN 933-8:2012  $\mathbb{A}$ .

This document includes Amendment 1 approved by CEN on 2015-04-19.

The start and finish of text introduced or altered by amendment is indicated in the text by tags A A.

This revised standard differs from EN 933-8:1999 for 0/2 mm size aggregates where the fines content was not limited to 10 %.

This European Standard is one of a series of standards for tests for geometrical properties of aggregates. Test methods for other properties of aggregates are covered by the following European Standards:

- EN 932, Tests for general properties of aggregates;
- EN 1097, Tests for mechanical and physical properties of aggregates;
- EN 1367, Tests for thermal and weathering properties of aggregates;
- EN 1744, Tests for chemical properties of aggregates;
- EN 13179, Tests for filler aggregate used in bituminous mixtures.

The other parts of EN 933, Tests for geometrical properties of aggregates, will be:

- Part 1: Determination of particle size distribution Sieving method;
- Part 2: Determination of particle size distribution Test sieves, nominal size of apertures;
- Part 3: Determination of particle shape Flakiness index;
- Part 4: Determination of particle shape Shape index;
- Part 5: Determination of percentage of crushed and broken surfaces in coarse aggregate particles;
- Part 6: Assessment of surface characteristics Flow coefficient of aggregates;
- Part 7: Determination of shell content Percentage of shells in coarse aggregates;
- Part 9: Assessment of fines Methylene blue test;
- Part 10: Assessment of fines Grading of filler aggregates (air jet sieving);

## EN 933-8:2012+A1:2015 (E)

#### — Part 11: Classification test for the constituents of coarse recycled aggregate.

According to the CEN-CENELEC Internal Regulations, the national standards organizations of the following countries are bound to implement this European Standard: Austria, Belgium, Bulgaria, Croatia, Cyprus, Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

# 1 Scope

This European Standard describes the reference method used for type testing and in case of dispute for the determination of the sand equivalent value of 0/2 mm fraction (for 0/4 mm, see Annex A) in fine aggregates or all-in aggregates. For other purposes, in particular factory production control, other methods may be used provided that an appropriate working relationship with the reference method has been established.

# 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 932-2, Tests for general properties of aggregates — Part 2: Methods for reducing laboratory samples

EN 932-5, Tests for general properties of aggregates — Part 5: Common equipment and calibration

EN 933-1, Tests for geometrical properties of aggregates — Part 1: Determination of particle size distribution — Sieving method

EN 933-2, Tests for geometrical properties of aggregates — Part 2: Determination of particle size distribution — Test sieves, nominal size of apertures

EN 1097-5, Tests for mechanical and physical properties of aggregates — Part 5: Determination of the water content by drying in a ventilated oven

# 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

## 3.1

## fines

particle size fraction of an aggregate which passes the 0,063 mm sieve

## 3.2

## laboratory sample

sample intended for laboratory testing

3.3

## particle size fraction (d<sub>i</sub>/D<sub>i</sub>)

fraction of an aggregate passing the larger (D<sub>i</sub>) of two sieves and retained on the smaller (d<sub>i</sub>)

NOTE The lower limit d<sub>i</sub> may be zero.

#### 3.4

#### subsample

sample obtained by means of a sample reduction procedure

#### 3.5

#### test portion

sample used as a whole in a single test



This is a free preview. Purchase the entire publication at the link below:

**Product Page** 

S Looking for additional Standards? Visit Intertek Inform Infostore

> Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation