



NSAI
Standards

Irish Standard
I.S. EN 62567:2013

Overhead lines - Methods for testing self-damping characteristics of conductors (IEC 62567:2013 (EQV))

I.S. EN 62567:2013

Incorporating amendments/corrigenda issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard – national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation - recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

<i>This document replaces:</i>	<i>This document is based on:</i> EN 62567:2013	<i>Published:</i> 22 November, 2013
This document was published under the authority of the NSAI and comes into effect on: 25 November, 2013		ICS number: 29.060 29.240.20 See CENELEC cover
NSAI 1 Swift Square, Northwood, Santry Dublin 9	T +353 1 807 3800 F +353 1 807 3838 E standards@nsai.ie W NSAI.ie	Sales: T +353 1 857 6730 F +353 1 857 6729 W standards.ie
Údarás um Chaighdeáin Náisiúnta na hÉireann		

English version

**Overhead lines -
Methods for testing self-damping characteristics of conductors
(IEC 62567:2013)**

Lignes électriques aériennes -
Méthodes d'essai des caractéristiques
d'auto-amortissement des conducteurs
(CEI 62567:2013)

Freileitungen -
Methoden zur Prüfung der
Eigendämpfungseigenschaften von
Leitern
(IEC 62567:2013)

This European Standard was approved by CENELEC on 2013-10-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 7/629/FDIS, future edition 1 of IEC 62567, prepared by IEC/TC 7 "Overhead electrical conductors" was submitted to the IEC-CENELEC parallel vote and approved by CENELEC as EN 62567:2013.

The following dates are fixed:

- latest date by which the document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2014-07-17
- latest date by which the national standards conflicting with the document have to be withdrawn (dow) 2016-10-17

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Endorsement notice

The text of the International Standard IEC 62567:2013 was approved by CENELEC as a European Standard without any modification.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-466	1990	International electrotechnical vocabulary (IEV) - Chapter 466: Overhead lines	-	-
IEEE Std. 563	1978	IEEE Guide on conductor self-damping measurements	-	-
IEEE Std. 664	1993	IEEE Guide for laboratory measurement of the power dissipation characteristics of aeolian vibration dampers for single conductors	-	-

This page is intentionally left BLANK.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Symbols and units	8
5 Test span arrangements	8
5.1 General	8
5.2 Span terminations	9
5.3 Shaker and vibration control system	10
5.4 Location of the shaker	12
5.5 Connection between the shaker and the conductor under test	12
5.5.1 General	12
5.5.2 Rigid connection	13
5.5.3 Flexible connection	14
5.6 Transducers and measuring devices	14
5.6.1 Type of transducers	14
5.6.2 Transducer accuracy	15
6 Conductor conditioning.....	16
6.1 General	16
6.2 Clamping	16
6.3 Creep	16
6.4 Running-in.....	16
7 Extraneous loss sources.....	16
8 Test procedures	17
8.1 Determination of span resonance	17
8.2 Power Method	18
8.3 ISWR Method	20
8.4 Decay method	22
8.5 Comparison between the test methods	24
8.6 Data presentation	25
Annex A (normative) Recommended test parameters.....	27
Annex B (informative) Reporting recommendations.....	28
Annex C (informative) Correction for aerodynamic damping	31
Annex D (informative) Correction of phase shift between transducers	33
Bibliography.....	34
Figure 1 – Test span for conductor self-damping measurements	9
Figure 2 – Rigid clamp	10
Figure 3 – Electro-dynamic shaker	11
Figure 4 – Layout of a test stand for conductor self-damping measurements.....	12
Figure 5 – Example of rigid connection	13
Figure 6 – Example of flexible connection	14
Figure 7 – Miniature accelerometer.....	15

Figure 8 – Resonant condition detected by the acceleration and force signals	18
Figure 9 – Fuse wire system disconnecting a shaker from a test span; this double exposure shows the mechanism both closed and open.	23
Figure 10 – A decay trace	24
Figure B.1 – Example of conductor power dissipation characteristics	29
Figure B.2 – Example of conductor power dissipation characteristics	30
Table 1 – Comparison of laboratory methods	25
Table 2 – Comparison of Conductor Self-damping Empirical Parameters	26
Table C.1 – Coefficients to be used with equation C-3	32

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**OVERHEAD LINES – METHODS FOR TESTING SELF-DAMPING
CHARACTERISTICS OF CONDUCTORS**
FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62567 has been prepared by IEC technical committee 7: Overhead electrical conductors.

The text of this standard is based on the following documents:

FDIS	Report on voting
7/629/FDIS	7/630/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Conductor self-damping is a physical characteristic of the conductor that defines its capacity to dissipate energy internally while vibrating. For conventional stranded conductors, energy dissipation can be attributed partly to inelastic effects within the body of the wires (hysteresis damping at the molecular level) but mostly to frictional damping, due to small relative movements between overlapping individual wires, as the conductor flexes with the vibration wave shape.

Self-damping capacity is an important characteristic of the conductors for overhead transmission lines. This parameter is a principal factor in determining the response of a conductor to alternating forces induced by the wind.

As the conductor self-damping is generally not specified by the manufacturer, it can be determined through measurements performed on a laboratory test span. Semi-empirical methods to estimate the self-damping parameters of untested conventional stranded conductors are also available but often lead to different results. Further, a great variety of new conductor types is increasingly used on transmission lines and some of them may have self-damping characteristics and mechanisms different from the conventional stranded conductors.

A "Guide on conductor self-damping measurements" was prepared jointly in the past by the IEEE Task Force on Conductor Vibration and CIGRE SC22 WG01, to promote uniformity in measuring procedures. The Guide was published by IEEE as Std. 563-1978 and also by CIGRE in Electra n°62-1979.

Three main methods are recognized in the above documents and divided into two main categories which are usually referred to as the "forced vibration" and "free vibration" methods.

The first forced vibration method is the "Power [Test] Method" in which the conductor is forced into resonant vibrations, at a number of tunable harmonics, and the total power dissipated by the vibrating conductor is measured at the point of attachment to the shaker.

The second forced vibration method, known as the "Standing Wave Method" or more precisely "Inverse Standing Wave Ratio [Test] Method" (ISWR), determines the power dissipation characteristics of a conductor by the measurement of antinodal and nodal amplitudes on the span, for a number of tunable harmonics.

The free vibration method named "Decay [Test] Method" determines the power dissipation characteristics of a conductor by measuring, at a number of tunable harmonics, the decay rate of the free motion amplitude following a period of forced vibration.

Several laboratories around the world have performed conductor self-damping measurements in accordance with the above mentioned Guide. However, large disparities in self-damping predictions have been found among the results supplied by the various laboratories. The causes of these disparities have been identified into five main points:

- 1) The different test methods adopted for the self-damping measurements.
- 2) The different span end conditions set up in the various test laboratories (rigid clamps, flexure members, etc.)
- 3) The different types of connection between the shaker and the conductor (rigid or flexible) and the different location of the power input point along the span.
- 4) The different conductor conditioning before the test (creep, running in, etc.)
- 5) The different manufacturing processes of the conductor.

OVERHEAD LINES – METHODS FOR TESTING SELF-DAMPING CHARACTERISTICS OF CONDUCTORS

1 Scope

The scope of this Standard is to provide test procedures based on the above-mentioned documents and devoted to minimize the causes of discrepancy between test results, taking into consideration the large experience accumulated in the last 30 years by numerous test engineers and available in literature, including a CIGRE Technical Brochure specifically referring to this standard (see Bibliography).

This Standard describes the current methodologies, including apparatus, procedures and accuracies, for the measurement of conductor self-damping and for the data reduction formats. In addition, some basic guidance is also provided to inform the potential user of a given method's strengths and weaknesses.

The methodologies and procedures incorporated in this Standard are applicable only to testing on indoor laboratory spans.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-466:1990, *International Electrotechnical Vocabulary. Chapter 466: Overhead lines*

IEEE Std. 563-1978, *IEEE Guide on conductor self-damping measurements*

IEEE Std. 664-1993, *IEEE Guide for laboratory measurement of the power dissipation characteristics of aeolian vibration dampers for single conductors*

3 Terms and definitions

For the purpose of this International Standard, the definitions of the International Electrotechnical Vocabulary (IEV) apply, in particular IEC 60050-466. Those which differ or do not appear in the IEV are given below.

3.1

conductor self-damping:

the self-damping of a conductor subjected to a tensile load T is defined by the power P_c dissipated per unit length by the conductor vibrating in a natural mode, with a loop length $\lambda/2$, an antinode displacement amplitude Y_0 and a frequency f

3.2

node

in a vibrating conductor, nodes are the points in which the vibration amplitude is the smallest

3.3

anti-node

in a vibrating conductor, anti-nodes are the points in which the vibration amplitude is the greatest

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- [Looking for additional Standards? Visit Intertek Inform Infostore](#)
 - [Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation](#)
-