



NSAI
Standards

Irish Standard
I.S. EN 50244:2016

Electrical apparatus for the detection of combustible gases in domestic premises - Guide on the selection, installation, use and maintenance

I.S. EN 50244:2016

Incorporating amendments/corrigenda/National Annexes issued since publication:

The National Standards Authority of Ireland (NSAI) produces the following categories of formal documents:

I.S. xxx: Irish Standard — national specification based on the consensus of an expert panel and subject to public consultation.

S.R. xxx: Standard Recommendation — recommendation based on the consensus of an expert panel and subject to public consultation.

SWiFT xxx: A rapidly developed recommendatory document based on the consensus of the participants of an NSAI workshop.

This document replaces/revises/consolidates the NSAI adoption of the document(s) indicated on the CEN/CENELEC cover/Foreword and the following National document(s):

NOTE: The date of any NSAI previous adoption may not match the date of its original CEN/CENELEC document.

This document is based on:

EN 50244:2016

Published:

2016-05-06

*This document was published
under the authority of the NSAI
and comes into effect on:*

2016-05-25

ICS number:

13.320

NOTE: If blank see CEN/CENELEC cover page

NSAI
1 Swift Square,
Northwood, Santry
Dublin 9

T +353 1 807 3800
F +353 1 807 3838
E standards@nsai.ie
W NSAI.ie

Sales:
T +353 1 857 6730
F +353 1 857 6729
W standards.ie

Údarás um Chaighdeáin Náisiúnta na hÉireann

National Foreword

I.S. EN 50244:2016 is the adopted Irish version of the European Document EN 50244:2016, Electrical apparatus for the detection of combustible gases in domestic premises - Guide on the selection, installation, use and maintenance

This document does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with this document does not of itself confer immunity from legal obligations.

In line with international standards practice the decimal point is shown as a comma (,) throughout this document.

This page is intentionally left blank

EUROPEAN STANDARD

EN 50244

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2016

ICS 13.320

Supersedes EN 50244:2000

English Version

Electrical apparatus for the detection of combustible gases in domestic premises - Guide on the selection, installation, use and maintenance

Appareils électriques pour la détection des gaz combustibles dans les locaux à usage domestique - Guide de sélection, d'installation, d'utilisation et de maintenance

Elektrische Geräte für die Detektion von brennbaren Gasen in Wohnhäusern - Leitfaden für Auswahl, Installation, Einsatz und Wartung

This European Standard was approved by CENELEC on 2016-03-14. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

EN 50244:2016 (E)**Contents**

Page

European foreword.....	3
Introduction.....	4
1 Scope	5
2 Normative references.....	5
3 Terms and definitions.....	5
4 Sensing of combustible gas	6
5 Types of apparatus	7
6 Installation	8
6.1 General	8
6.2 Gas releases	8
6.2.1 General.....	8
6.2.2 Source of the gas escape	8
6.2.3 Examples of behaviour of gas releases	9
6.2.4 Positioning of the gas detector	10
6.3 Remote Detector Heads	12
6.4 Mains power supply	12
7 Executive functions (type A apparatus only).....	13
7.1 General	13
7.2 Shut-off valve	13
7.3 Ventilation fan	13
7.4 Main electric switch.....	13
7.5 Remote alarm	13
7.6 Additional visual alarm	13
7.7 Link between detector and ancillary device	13
7.8 Fault relays	13
8 Advice to the user	14
8.1 Manufacturer's instructions	14
8.2 Location	14
8.3 Power supply	14
8.4 Indicators	14
8.5 Alarms.....	14
8.6 Maintenance	15
8.7 Lifetimes.....	15
9 Emergency actions.....	15
Bibliography	16

European foreword

This document (EN 50244:2016) has been prepared by CLC/TC 216 “Gas detectors”.

The following dates are fixed:

- latest date by which this document has to be (dop) 2017-03-14
implemented at national level by publication of
an identical national standard or by
endorsement
- latest date by which the national standards (dow) 2019-03-14
conflicting with this document have to
be withdrawn

This document supersedes EN 50244:2000.

EN 50244:2016 includes the following significant technical changes with respect to EN 50244:2000 (various minor changes have also been made):

- General information added to cover domestic premises, boats and caravans. This is a result of the splitting of EN 50194 into EN 50194-1 and EN 50194-2.
- In Clause 4 text has been added regarding alarm set points for apparatus complying with EN 50194-1.
- A new Clause 5 has been created to provide further information to the user concerning the differences between Type A and Type B devices.
- Former Clause 5 has been renumbered Clause 6, text has been reformulated to avoid repetition and make it easier to understand.
- New Figures 1 and 2 created, to show the typical locations of combustible gas alarms when used with Natural Gas and LPG installations.
- The text in Clause 7 “Executive Actions” has been aligned with EN 50292, where applicable, for combustible gas alarms.
- In Clause 8 “Advice to the User”, additional text has been added to highlight the differences between location of a combustible gas detector and a carbon monoxide alarm.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

EN 50244:2016 (E)

Introduction

This European Standard is intended to be a guide for people who, in the course of their professional activities, are required to install combustible gas detectors in domestic premises. It is also aimed at anyone who might supply such gas detectors to members of the public for subsequent installation by competent persons according to national regulations, so that advice may be given based on good engineering practice.

Apparatus for the detection of combustible gases are not a substitute for good gas installation practice and regular servicing of gas appliances, although they may provide an added margin of reassurance for users of gaseous fuels. Domestic combustible gas detectors with or without some form of executive function may overcome fears of fuel safety and can be particularly beneficial in certain circumstances.

1 Scope

This European Standard provides information on the selection, installation, use and maintenance of apparatus for the detection of combustible gas designed for continuous operation in a fixed installation in domestic premises as described in the EN 50194 series. This guide should be read in conjunction with any additional relevant national or local regulations.

The European Standard refers to the installation of two types of apparatus designed to operate in the event of an escape of town gas, natural gas or liquefied petroleum gas:

- Type A apparatus - to provide a visual and audible alarm and an executive action in the form of an output signal that may actuate directly or indirectly a shut-off device and/or other ancillary device;
- Type B apparatus - to provide visual and audible alarms only.

This guide is not applicable to the use of apparatus:

- for the detection of toxic gases such as carbon monoxide, see EN 50292;
- for industrial or commercial premises, see EN 60079-29-2.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 1775, *Gas supply - Gas pipework for buildings - Maximum operating pressure less than or equal to 5 bar - Functional recommendations*

EN 50194 (all parts), *Electrical apparatus for the detection of combustible gases in domestic premises*

EN 60079-29-2, *Explosive atmospheres — Part 29-2: Gas detectors — Selection, installation, use and maintenance of detectors for flammable gases and oxygen (IEC 60079-29-2)*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

lower explosive limit

LEL

volume ratio of combustible gas or vapour in air below which an explosive gas atmosphere will not be formed

3.2

upper explosive limit

UEL

volume ratio of combustible gas or vapour in air above which an explosive gas atmosphere will not be formed

3.3

continuous operation

apparatus which is continuously powered with continuous or intermittent automatic sensing

This is a free preview. Purchase the entire publication at the link below:

[Product Page](#)

-
- Looking for additional Standards? Visit Intertek Inform Infostore
 - Learn about LexConnect, All Jurisdictions, Standards referenced in Australian legislation
-